




151 Industrial Park RdA
 Colborne, ON K0K 1S0
 905-355-3281



**Intermediate Class Surge Arrester
 3kV Nom. 2.55kV MCOV
 Silicone**

SURGE ARRESTER PERFORMANCE DATA			
NO.	ITEM	DATA	UNIT
6	ARRESTER CLASS	INTERMEDIATE	
7	RATED VOLTAGE	3	kV
8	CONTINUOUS OPERATING VOLTAGE (MCOV)	2.55	kV
9	NOMINAL DISCHARGE CURRENT	10	kA
10	CREEPAGE DISTANCE	5.11	In.

PRODUCT	3KV SILICONE SURGE ARRESTER
PART NUMBER	502LAI3 (YH10W-3)

Manufacturing Standard: IEEE C62.11